

**Development of District Energy Supply Business  
by Introducing Co-generation**  
(FY2015 JCM Feasibility Study, Ministry of Environment, Japan)

**February, 2016**




# 1. Overview of JCM FS

## a. Project Location

- Central Jakarta

## b. Description of the technology




## c. Indonesia Partner

- Local Real Estate Developer (A Company)

# 1. Overview of JCM FS

## d. Project Detail


### Project Scope



# 1. Overview of JCM FS

## d. Project Detail

### Electricity Demand



### Heat Demand

Building/Facility	Floor Area [m <sup>2</sup> ]	Annual Demand [TJ/year]
Office	26,464	33
Sky Bridge	7,110	16
Hotel	11,880	11
Apartment	37,584	37
<b>Total</b>	<b>83,038</b>	<b>98</b>

### Input / output condition

	Item	Value
<b>INPUT</b>	Electricity Consumption	6.5 [GWh/year]
	Gas Consumption	6.9×10 <sup>6</sup> [m <sup>3</sup> /year] ( 73 [GWh/year] )
	Water Consumption	1.4×10 <sup>5</sup> [m <sup>3</sup> /year]
<b>OUTPUT</b>	Electricity Sale	35 [GWh/year]
	Cold Heat Sale	98 [TJ/year] ( 27 [GWh] )

# 1. Overview of JCM FS

## d. Project Detail

### Current Situation of Electricity and Gas Supply in Jakarta

	Office Building A	Office Building B	Hotel	Commercial Building
Frequency of Blackout	Once/Month	3 to 4 times/year	Once/Month	—
	(Max two hours)	(2 hours/time)	(Mainly voltage drop)	(N.A.)
Frequency of Gas Supply Stop	Twice/year	(N.A.)	Once	Once/5 years

### Gas Engine Example in Jakarta



- Plaza Indonesia is a large shopping mall in Jakarta (Started since 2009, net floor area: aprox 62,747 m<sup>2</sup>) .
- Electricity from gas engine make up 75% of total demand (as long as we know). No use for wasted heat.

- **Co-generation system is still unpopular in Jakarta especially commercial market.**
- **Spread of energy saving system also contributes to sustainable society in addition to power plant expansion.**

# 1. Overview of JCM FS

## d. Project Detail

### Perspective of Government and State-owned Companies


<b>ESDM</b>	<ul style="list-style-type: none"><li>• ESDM anticipates private sector's investment on electricity business as the electricity generation capacity is not sufficient in Indonesia.</li><li>• Basically one electricity company shall be in one business area for public electricity supply under the current electricity regulation.</li><li>• If current electricity company's supply is not enough, other company is able to obtain business area.</li></ul>
<b>PLN</b>	<ul style="list-style-type: none"><li>• PLN supposes the electricity capacity is sufficient in Jakarta.</li><li>• Business area may be given to private company where it is difficult for PLN to supply.</li></ul>
<b>PGN</b>	<ul style="list-style-type: none"><li>• PGN is supportive for installing cogeneration system.</li></ul>

- **If the business area license were open to private company, more business opportunity born and energy efficient technology could be adopted.**


# 1. Overview of JCM FS

## d. Project Detail

### Considerable Business Scheme



# 2. Reference Scenario



- **Characteristics of the Project**
  - Produce electricity by gas engine, which is operated by natural gas, to supply electricity to the complex buildings
  - Produce cold-heat by absorption chiller, which is operated by waste heat out of the gas engine, to supply air-conditioning service to the complex facility
- **Reference Scenario**
  - Electricity from the national power grid
  - Cold-heat from electric chiller operated by electricity from the national power grid



# 3. Monitoring Methods

Double Check / Feasibility Check / Monitor Accuracy Check

Category	Check Item	Technical manager· Staff	Financial manager	Calibration Staff	Reference
Natural Gas	Supply status / Amount	○	-	○ (International standards)	Gas meter Invoices
	Price / Amount	-	○	-	Invoices
Electricity	Supply status / Amount	○	-	○ (International standards)	Electricity meter
	Price/ Amount	-	○	-	Invoices
CO2 Emissions		○	○	-	MRV report
Maintenance Cost		○ (Operation cost)	○ (maintenance cost)	-	Invoices Working records
Feasibility check		-	○	-	Reference electricity price check

# 4. Quantification of GHG Emissions and their reductions

- **Condition**

- Electricity demand of the complex facility: 35 GWh/year
- Cold-heat demand of the complex facility: 98 TJ/year
- Natural gas consumption for gas engine: 243 TJ/year
- Natural gas consumption for gas-fired absorption chiller: 21 TJ/year
- Electricity received from power grid: 6.5 GWh/year



- **Reference Emission**

- 33,313 tCO<sub>2</sub>/year

CO<sub>2</sub> emission factor of the grid: 0.843 tCO<sub>2</sub>/MWh (Latest Emission Factor, JAMALI, Ex-ante)

COP of centrifugal chiller: 5.94 (ID\_AM002 “Energy Saving by Introduction of High Efficiency Centrifugal Chiller”)

- **Project Emission**

- 20,321 tCO<sub>2</sub>/year


CO<sub>2</sub> emission factor of the grid: 0.843 tCO<sub>2</sub>/MWh (Latest Emission Factor, JAMALI, Ex-ante)

CO<sub>2</sub> emission factor of natural gas: 56.1 t CO<sub>2</sub>/TJ (2006 IPCC Guidelines for National Greenhouse Gas Inventories Volume 2 Energy)

- **GHG Emission Reductions**

- GHG Emission Reductions = Reference Emission – Project Emission
- = 33,313 tCO<sub>2</sub>/year – 20,321 tCO<sub>2</sub>/year = 12,992 tCO<sub>2</sub>/year

# 5. MRV Methods



# 6. Capacity Building Plan / 7. Others

## 6. Capacity Building Plan

- Co-generation system design and Operation knowhow will transferred.

## 7. Others

Investment	Category	Cost
	Equipment [billion Rp]	64
	Building [billion Rp]	5
	Total [billion Rp]	69

### Condition

Corporate Income Tax: 25%

Depreciation Period (20 yrs for building, 16 yrs for facilities)

Exchange Rate: Rp. 13,333/US\$, Rp. 110/JPY

Operation Period: 17 years (2 yrs for construction, 15 yrs for operation)

### Pay Back periods

11 years

**If are there any opportunity adopting co-generation system in Indonesia, please contact to JGC !**